



Ref. Certif. No.

BE-48332

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Energy Storage Systems (Product name: Energy Storage Li-ion Battery)

Name and address of the applicant

Wuxi Solinteg Power Co., Ltd.
Building H1-1001, No.6 Jingxian Road, Xinwu District, 214135
Wuxi, Jiangsu Province, China

Name and address of the manufacturer

Wuxi Solinteg Power Co., Ltd.
Building H1-1001, No.6 Jingxian Road, Xinwu District, 214135
Wuxi, Jiangsu Province, China.

Name and address of the factory

WeCo (Guangdong) Energy Storage Technology Co., Ltd
Building 1, No.2 of Zhengda Road, Chukeng, Dongkeng District,
Dongguan, Guangdong, China

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

For battery module:

Rated Voltage: 51,2 Vd.c.; Rated Capacity: 105 Ah

Operating voltage range: 46,5 Vd.c. to 58,4 Vd.c.

Operating temp. range: 0 to 55 °C (charge), -20 to 55 °C (discharge)
Class I

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EBR-B5K3-A

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

National Differences:

EU Group Differences, EU Special National Conditions, AU, NZ

SUES240500081301

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

SGS Belgium NV - Division SGS CEBEC
Riverside Business Park
Bld Internationalelaan 55, Building A
B-1070 Brussels, Belgium



Date: 2024-06-07

Signature: Mark Lohmann